

NOTICE INVITING QUOTATION

Sealed quotations are hereby invited by the undersigned on behalf of the Director, IISER Pune for the work mentioned below up to **3.00 PM on 15/06/2020** from approved and eligible contractors registered with CPWD, Maharashtra State PWD, Railways, MES in appropriate category for electrical/ (B&C) works for the work mentioned below. The quotations will be opened at 3.30 PM on the same day.

Name of work: - Annual servicing and oil filtration of 1000, 750 & 630 KVA Transformer at ASB 1 & 2, IISER Pune.

Issue to –

Name and address of the agency –

Terms and Conditions:

- 1) The applicant should be registered (**ANY ONE**) with CPWD in western region, Maharashtra State PWD, MES, Railways in appropriate category for electrical / (B & C) works OR Specialized expert agency/Authorized dealer/service provider of Transformers. The registration certificate should be valid till the last date of receipt of tender. Applicant should submit attested or notarized copies of the valid registration certificate and work completion certificate along with quotation.
- 2) Time period for completion of work shall be **30 (Thirty)** days from the date of placing the work order by IISER Pune. The act of backing-out after quotation will debar such agencies for participating in future quotations of IISER PUNE. Bidder may e-mail queries on maintenance@iiserpune.ac.in or submit to IISER PUNE office in hard copy on all working days before a day of submission date of quotation.
- 3) Quotation can be obtained from IISER PUNE Engineering office at Main Building between 10 AM to 4 PM on all working days before date of submission. Applicant may quote by downloading quotation document from IISER PUNE website.
- 4) All agencies need to submit their quotation in hard copy in a sealed envelope to this office by suitable means on and before **3 PM on 15/06/2022**. Quotation received after the date & time specified above shall not be accepted. Any delays, postal delay etc. will not be entertained. Agency should quote for all the items in the BOQ. The bid shall be submitted in the original Bid document (as issued by the IISER, Pune) super scribing the name of work. Rates quoted in the words shall be treated as final for deciding L1 bidder.
- 5) Quotations will be opened on the same day (**15/06/2022**) at **3.30 PM** in the presence of agency or their authorized representatives, if any. The offer of the agency should be commercially clear



including acceptance of all terms and conditions of this Quotation by the agency. IISER Pune reserves the right to accept or reject the quotation/s without assigning any reasons.

- 6) Quotations submitted with any conditions shall be treated as 'Conditional Quotation' and shall be summarily be rejected by IISER PUNE.
- 7) Quoted rates should be inclusive of cost of all the materials, labour cost , GST , all taxes, octroi, duties, cost of sample and fees towards testing of materials in labs, royalties etc. complete. Nothing extra shall be paid separately.
- 8) All approved makes shall be as per list attached with this and as per CPWD and manufactures specifications. Agency should put-up technical data and obtain prior approval on makes of various materials of IISER PUNE before taking-up work.

The successful agency shall make his own arrangement for all Tools & tackles for work etc complete in view of completion of work. Electricity shall be provided free of cost to agency at one source, agency should make own arrangement to safely tap of power from source to work location.

No advance payment shall be made by IISER Pune.

Quoted rates should be including GST, TDS and other applicable taxes and cess will be deducted from the bills of the work as applicable.

- 9) Specification for the work to be carried out as per BOQ, latest CPWD specification, IS specifications, manufactured specification & as per instruction of IISER PUNE whenever specification CPWD/ IS specification are not available.
- 10) The contractor shall ensure that minimum wages should be paid to the labours and employees in accordance with labour laws.
- 11) L1 Agency to submit actual measurements and abstract sheet to IISER PUNE within 30 days from completion of work.


Superintending Engineer,
IISER Pune

Encl: - 1. Schedule of Quantity
2. Approved Make list for electrical

Sign & stamp of Agency-



APPROVED MAKELIST FOR ELECTRICAL		
S.No.	Material	USER PUNE Make
1	Instrument Transformers Indicating Meters	Kappa/Kalpa/Voltamp
2	Analog	Meco/Rishab/AE/HPL
3	Digital	Meco/AE/ Socomec/Conzerv/SECURE/HPL
4	Indicating Lamps	GE/SCHNEIDER/ Teknic/L&T/ALTOS, (MULTIPLE LEDs)
5	PLC / Digital Load Monitor / Power monitor	Electrex/Allen Bradley/GE/Schneider/Conzerv
6	Panel Accessories / Terminal block	Dirak/Elmax/phoenix/Wago
7	Timers	L & T/Minilec/ Siemens/ GE/ Schneider
8	TVSS	ASCO /Schneider/ABB
9	Cable Terminating Kits	Raychem Heat Shrinkable/3M/CCI
10	Earthing	Erico/Nimbus/Ashlok
11	MV Switch Boards (LT panels)	Accusonic /Load Controls /Elins / Lotus Switchgear / Pace Switch gears/ Suvarna Electricals
12	Moulded Case Circuit Breaker	GE (Spectra / Record)/Schneider (COMPACT)/ L & T (O SINE)/ABB/MDS Legrand
13	MCB Distribution Board	Legrand/Schneider /Siemens
14	Miniature Circuit Breaker	MIK/Legrand /Siemens/Schneider
15	ELCB / RCBO	MIK/Legrand /Siemens/Schneider
16	Earth Leakage Relay	MIK/Legrand /Siemens/Schneider
	IT Cables (XLPE)	Polycab/Finox/CCI



18	PVC Insulated copper wire FRLS	Polycab/Finolex/CCI
19	Cable Glands	Dowells/SMI/CCI/Electrowerke
20	PVC Rigid conduits	Precision/DIAMOND/Finolex/Polycab
21	M S Conduits	BEC/BI,
22	Switches, Sockets, Plug etc	Legrand Mosaic/MK/Schneider/ Anchor(Ave)
23	Ceiling rose / HOLDERS	Legrand Mosaic/MK/Schneider/ Anchor(Ave)
24	Light fitting, Flourscent CFL/GLs	Philips / Wipro/ GE
25	LED Light fitting	Wipro/Asian/Siska /Philips
26	Ceiling Fan	Crompton greaves (high breeze)/ Bajaj Super Model /Usha
27	Exhaust Fans	Alstom/Almonard/Usha/CGL
28	Telephone Cables	Delton/Finolex/ Polycab
29	Telephone Sockets	Anchor /MK (Suitable to mount on Legrand DLP trunking) /
30	Terminal Junction boxes	Elmex
31	Power Socket Industrial type	Legrand Mosaic/Mk/Schneider,
32	TV Outlet	Anchor/Legrand/MK
33	Cable trays	Storax/ Skaber/Profab
34	Metallic raceways	Storax/ Skaber/Profab
35	PVC raceways / PVC DLP trucking	LEGRAND/ MK/Schneider
36	Aluminium raceways	LEGRAND/ MK/Schneider
37	Surface / Recess mounted FTL fixtures	Philips/Wipro/GE
38	Recess mounted down lighter	Philips/Wipro/GE
39	Wall mounted luminaire	Philips/Wipro/GE
40	Data Cable - CAT-6	D-Link/Legrand/Polycab
41	External light fittings/ Garden Light fittings	Philips/Wipro /GE/Philips
42	Base plates and face plates	Legrand Mosaic/ MK/Schneider/Anchor



43	Full loaded patch panels	D link or RR
44	Data patch cords	D link or RR
45	Fire Alarm Control Panel	Notifier / Edward / Bosch / Cooper/ Siemens
46	Repeater Panel	Notifier / Edward / Bosch / Cooper/ Siemens
47	Addressable Smoke Detector	Notifier / Edward / Bosch / Cooper/ Siemens
48	Addressable Multi Sensor Detector	Notifier / Edward / Bosch / Cooper/ Siemens
49	Addressable Heat Detector	Notifier / Edward / Bosch / Cooper/ Siemens
50	Addressable Strobe Cum Sounder	Notifier / Edward / Bosch / Cooper/ Siemens
51	Addressable Sounder / Hooter	Notifier / Edward / Bosch / Cooper/ Siemens
52	Addressable Manual Call point	Notifier / Edward / Bosch / Cooper/ Siemens
53	Addressable Monitor Module	Notifier / Edward / Bosch / Cooper/ Siemens
54	Addressable Control Module	Notifier / Edward / Bosch / Cooper/ Siemens
55	FRLS Armoured Cable	Finolex / Polycab / Lapp
56	Other Items	Approval of Engineer In charge.
57	Isolation Transformer	Numeric Digital system (Novature)/ Neelkanth power solution/Ador powertrans



Scheduled Of Quantity

Name of work : Annual servicing and oil filtration of 1000, 750 & 630 KVA at ASB 1 & 2, IISER Pune.

Note : Please note that quoted rates are inclusive of all taxes, labor, transportation etc. Nothing extra shall be paid separately.

Sr.No	Description	Qty.	Unit	Rates in words and figure	Amount
1	Transformer oil filtration for main tank of 1000 KVA oil filled distribution transformer with filter machine having filtration, vacuum pump, heating elements, temp gauges, etc. on wheel with vehicle. Job will be considered after getting desire BDV value of filtered oil.	4	Nos		
2	Transformer oil filtration for OLTC tank of 1000 KVA oil filled distribution transformer with filter machine having filtration, vacuum pump, heating elements, temp gauges, etc. on wheel with vehicle. Job will be considered after getting desire BDV value of filtered oil.	4	Nos		
3	Transformer oil filtration for main tank of 630 KVA oil filled distribution transformer with filter machine having filtration, vacuum pump, heating elements, temp gauges, etc. on wheel with vehicle. Job will be considered after getting desire BDV value of filtered oil.	2	Nos		
4	Transformer oil filtration for main tank of 750 KVA oil filled distribution transformer with filter machine having filtration, vacuum pump, heating elements, temp gauges, etc. on wheel with vehicle. Job will be considered after getting desire BDV value of filtered oil.	1	Nos		
5	Breakdown value test for Transformer oil at site with calibrated equipment and meters. Detailed report should be submitted by the agency with proper format (Before filtration)	11	Nos		
6	Breakdown value test for Transformer oil at site with calibrated equipment and meters. Detailed report should be submitted by the agency with proper format (After filtration)	11	Nos		



7	Acidity test for transformer oil at Lab. Detailed report should be submitted by the agency with proper format.	11	Nos		
8	Periodic Servicing & testing of protective devices like oil temp / winding temp with HT panel for each transformer.	7	Nos		
9	I R testing of transformer winding for each transformer.	7	Nos		
10	Testing of earth pit with calibrated earth tester for HT and LT installations.	50	Nos		
11	Supply and replacement of silica gel breather with glass container, gel and other accessories. (for 630 & 1000 KVA transformer)	3	Nos		
12	Supply and replacement of silica gel into existing breather of 1000 KVA transformer	10	kg		
13	Supply and replacement of Transformer oil (IS335) for topping for transformer and OLTC	300	Liter		
14	To & fro transport charges for filter machine upto site location , Required electric supply for filter machine will be provided by IISER Pune (Required labour, technician, engineer, for above said work is in scope of agency,)	4	Nos		
15	Insulation test for transformer & OLTC. Detailed report should be submitted by the agency with proper format.	11	Nos		
	Total (Including All)				

Sign and Stamp of Agency

Superintending Engineer, IISER Pune

