



भारतीय विज्ञान शिक्षा और अनुसंधान संस्थान, पुणे
(शिक्षा मंत्रालय, भारत सरकार का एक स्वायत्त संस्थान)
मुख्य भवन, आईआईएसईआर परिसर डॉ. होमी भाबा रोड, पुणे-411 008।
फोन नंबर 020 2590 8082 फैक्स 020 2588 7499/2589 8022

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH PUNE

(An Autonomous Institution of the Ministry of Education, Govt. of India)
Main Lab Building, IISER Pune Campus, Dr. Homi Bhaba Road, Pune-411 008.
Ph No 020 2590 8082 Fax 020 2590 8082

Corrigendum 01

Date: 03 04 2023

Name of work: Augmentations of HPC Cluster room at Chemistry First Floor Data Centre at IISER Pune.
NIT NUMBER: 23/IISER/PUNE/2022-23


Tender Id: 2023_IISRP_744755_1

With tender reference no. 23/IISER/Pune/2022-23 dated 15/03/2023 for above noted work. The intending bidder shall take note of following.

S.N.	Bidder Queries	IISER Clarification
1	Tender mentions - "Backward curved Radial Type Evaporator Fan with direct drive variable speed EC Motor "We request you to also approve Axial Type Evaporator fan with direct drive variable speed EC motor.	Please read as "Backward curved Radial Type/Axial type Evaporator Fan with direct drive variable speed EC Motor"
2	Tender mentions - "Oil separator " For such small capacity compact units' oil separator cannot be provided and not reqd. Request for your approval and acceptance.	Please considered refrigeration circuit with /without oil separator.
3	Tender mentions - " ODU unit arrangement: The unit design allows a quick fan replacement without the need of stopping the entire cooling, granting the full availability (Hot Swappable arrangement reqd.). "The hot swappable arrangement should be for Indoor unit and not ODU. Request you to pl change the same	Please read as "IDU unit arrangement: The unit design allows a quick fan replacement without the need of stopping the entire cooling, granting the full availability (Hot Swappable arrangement reqd.)"
4	Last date of bid submission is 30th March. We request you to please provide extension of 10days for the bid submission as it involves lot of working to be done and will not be possible to submit till 30 March'2023	Last date of tender extended till 06 04 2023 upto 15:00 HRS

No change in other Tender Conditions, Specifications, BOQ, Quantity, units, Original tender documents and conditions published stands as it is.

Above Corrigendum 01 shall form part of tender. Bidders are requested to take note of above Corrigendum 01 and quote rates accordingly. Corrigendum 01 shall be made available on Institute website and e-procurement portal for bidder's reference.


Superintending Engineer

IISER Pune