



भारतीय विज्ञान शिक्षा और अनुसंधान संस्थान, पुणे
INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH PUNE
(शिक्षा मंत्रालय, भारत सरकार का एक स्वायत्त संस्थान)
(An Autonomous Institution of the Ministry of Education, Govt. of India)

IISER PUNE campus, Dr. Homi Bhaba Road, Pune-411 008.
आई.आई.एस.ई.आर पुणे परिसर, डॉ होमी भाबा रोड, पुणे-411 008

No: 54(2) /IISER/Pune/2023-24/ 92

Dated 20-07-2023

कोटेशन आमंत्रित करने की सूचना
NOTICE INVITING QUOTATION

सीपीडब्ल्यूडी, महाराष्ट्र राज्य पीडब्ल्यूडी, रेलवे और एमईएस में से किसी के साथ पंजीकृत अनुमोदित और पात्र ठेकेदारों से 25/07/2023 को दोपहर 3.00 बजे तक नीचे उल्लिखित कार्य के लिए निदेशक, आईआईएसईआर पुणे की ओर से अधोहस्ताक्षरी द्वारा मुहरबंद कोटेशन आमंत्रित किए जाते हैं। इलेक्ट्रिकल (बी एंड सी) कार्यों के लिए उपयुक्त श्रेणी में या आरओ सिस्टम या वाटर कूलर की आपूर्ति, स्थापना परीक्षण, कमीशनिंग और रखरखाव के क्षेत्र में विशेष विशेषज्ञ एजेंसी। कोटेशन उसी दिन अपराह्न 3.30 बजे खोली जाएंगी।

Sealed quotations are hereby invited by the undersigned on behalf of the Director, IISER Pune for the work mentioned below up to 3.00 PM on 27/07/2023 from approved and eligible contractors registered with anyone of CPWD, Maharashtra State PWD, Railways, and MES in appropriate category for electrical (B&C) works OR specialized expert agency in field of Supply, installation testing, commissioning and maintenance of RO System or water cooler. The quotations will be opened at 3.30 PM on the same day.

कार्य का नाम: - मुख्य भवन, आईआईएसईआर पुणे की चौथी और पांचवीं मंजिल के लिए 150 लीटर वॉटर कूलर की आपूर्ति, स्थापना, परीक्षण और कमीशनिंग।

एजेंसी का नाम और पता

Name of Work: -Supply, Installation, Testing & Commissioning of 150 Ltr Water Cooler for 4th and 5th Floor of Main Building, IISER Pune.

Name and address of the agency –

नियम और शर्तें:

- आवेदक को इलेक्ट्रिकल (बी एंड सी) कार्यों के लिए उपयुक्त श्रेणी में सीपीडब्ल्यूडी, महाराष्ट्र राज्य पीडब्ल्यूडी, रेलवे, एमईएस में से किसी के साथ पंजीकृत और पात्र ठेकेदार होना चाहिए या आरओ सिस्टम या पानी कूलर की आपूर्ति, स्थापना परीक्षण, कमीशनिंग और रखरखाव के क्षेत्र में विशेष विशेषज्ञ एजेंसी होनी चाहिए। आवेदक को कोटेशन के साथ समापन प्रमाण पत्र की प्रति के साथ ग्राहक विभाग से पिछले तीन वर्षों के भीतर पूरे किए गए कार्य के अनुभव प्रमाण पत्र की प्रमाणित या नोटरीकृत प्रतियां जमा करनी चाहिए। न्यूनतम पात्रता मानदंडों को पूरा नहीं करने वाले बोलीदाताओं को सरसरी तौर पर अस्वीकार कर दिया जाएगा।
- कोटेशन खोलने के बाद बैंक कार्य पूरा करने की समय अवधि IISER पुणे द्वारा कार्य आदेश देने की तिथि से 30 दिन होगी। आउट का कार्य ऐसी एजेंसियों को आईआईएसईआर पुणे के भविष्य के कोटेशन में भाग लेने से वंचित कर देगा। बोलीदाता maintenance@iiserpune.ac.in पर प्रश्न ई मेल कर सकते हैं या उपरोक्त निर्दिष्ट कोटेशन की-तारीख जमा करने से एक दिन पहले सभी कार्य दिवसों पर हार्ड कॉपी में आईआईएसईआर पुणे कार्यालय में जमा कर सकते हैं।

Sign & Stamp of Agency



3. कोटेशन आमंत्रण नोटिस (एनआईक्यू) दस्तावेज आईआईएसईआर पुणे से 121, इंजीनियरिंग अनुभाग, मुख्य भवन, आईआईएसईआर पुणे परिसर, डॉ. होमी भाभा रोड, पाषाण, पुणे - 411008 पर सभी कार्य दिवसों पर सुबह 10 बजे से शाम 4 बजे के बीच प्राप्त किया जा सकता है। जमा करने की तिथि। आवेदक IISER PUNE वेबसाइट <http://www.iiserpune.ac.in/links/tender-notices-and-eoi> से NIQ दस्तावेज़ प्राप्त करके कोटेशन जमा कर सकते हैं।
4. सभी एजेंसियों को दो अलग-अलग लिफाफों वाले सीलबंद लिफाफे में हार्ड कॉपी में अपना कोटेशन जमा करना होगा, एक लिफाफा जिसमें क्लॉज 1 में उल्लेखित योग्यता दस्तावेज और दूसरा लिफाफा जिसमें साइन, स्टाम्प, एनआईक्यू दस्तावेज शामिल हैं, इस कार्यालय को उचित माध्यम से और पहले जमा करने की अंतिम तिथि और समय। ऊपर निर्दिष्ट तिथि और समय के बाद प्राप्त कोटेशन स्वीकार नहीं किया जाएगा। किसी भी देरी, डाक देरी आदि पर विचार नहीं किया जाएगा। एजेंसी को बीओक्यू में सभी मदों के लिए कोट करना चाहिए। बोली को मूल बोली दस्तावेज (आईआईएसईआर, पुणे द्वारा जारी किए गए अनुसार) में कार्य के नाम के ऊपर लिखा हुआ प्रस्तुत किया जाएगा। शब्दों में उद्धृत दरों को एल1 बोलीदाता तय करने के लिए अंतिम माना जाएगा। कोटेशन उसी दिन (27/07/2023) अपराह्न 3.30 बजे एजेंसी या उनके अधिकृत प्रतिनिधियों, यदि कोई हो, की उपस्थिति में खोले जाएंगे। कृपया उल्लेख करें - तकनीकी/अर्हता बोली लिफाफे-1 पर एवं वित्तीय बोली लिफाफे-2 पर।
5. कोटेशन उसी दिन अपराह्न बजे एजेंसी या उनके अधिकृत प्रतिनिधियों 3.30, यदि कोई हो, की उपस्थिति में खोली जाएगी। एजेंसी का प्रस्ताव व्यावसायिक रूप से स्पष्ट होना चाहिए जिसमें एजेंसी द्वारा इस कोटेशन के सभी नियमों और शर्तों की स्वीकृति शामिल है। आईआईएसईआर पुणे बिना कोई कारण बताए कोटेशन को स्वीकार या अस्वीकार करने का अधिकार सुरक्षित रखता है।
6. किसी भी शर्त के साथ जमा किए गए कोटेशन को सशर्त कोटेशन माना जाएगा और आईआईएसईआर पुणे द्वारा सरसरी तौर पर खारिज कर दिया जाएगा।
7. उद्धृत दरों में सभी सामग्रियों की लागत, श्रम लागत, जीएसटी, सभी कर, चुंगी, शुल्क, नमूने की लागत और प्रयोगशालाओं में सामग्री के परीक्षण के लिए शुल्क, रॉयल्टी आदि शामिल होना चाहिए। अतिरिक्त कुछ भी अलग से भुगतान नहीं किया जाएगा। नहीं, बोलीदाता अपनी बोली से संबंधित किसी भी मामले में बोली खुलने के समय से कार्य आदेश जारी करने के समय तक आईआईएसईआर, पुणे से संपर्क करेगा। बोलीदाता द्वारा आईआईएसईआर के बोली मूल्यांकन, बोली तुलना या अनुबंध पुरस्कार निर्णयों को प्रभावित करने के किसी भी प्रयास के परिणामस्वरूप उसकी बोली को अस्वीकार किया जा सकता है।
8. सभी स्वीकृत निर्माण बीओक्यू में निर्दिष्ट के अनुसार होंगे और सीपीडब्ल्यूडी विनिर्देशों के अनुसार, एजेंसी को तकनीकी डेटा डालना चाहिए और काम शुरू करने से पहले आईआईएसईआर पुणे की विभिन्न सामग्रियों के निर्माण पर पूर्व अनुमोदन प्राप्त करना चाहिए। सफल एजेंसी कार्य पूरा होने के मद्देनजर कार्य आदि के लिए सभी उपकरण और टैकल की अपनी व्यवस्था स्वयं करेगी। एजेंसी को एक स्रोत पर बिजली निःशुल्क उपलब्ध कराई जाएगी, एजेंसी को स्रोत से कार्य स्थल तक सुरक्षित रूप से बिजली के दोहन की व्यवस्था स्वयं करनी चाहिए। आईआईएसईआर पुणे द्वारा कोई अग्रिम भुगतान नहीं किया जाएगा। उद्धृत दरों में जीएसटी, टीडीएस और अन्य लागू कर शामिल होने चाहिए। काम के बिल से इनकम टैक्स और लेबर सेस की कटौती की जाएगी।
9. बीओक्यू नवीनतम सीपीडब्ल्यूडी विनिर्देश, आईएस विनिर्देशों और आईआईएसईआर पुणे के निर्देश के अनुसार जब भी सीपीडब्ल्यूडी आईएस विनिर्देश उपलब्ध नहीं हैं /, के अनुसार किए जाने वाले कार्य के लिए विशिष्टता।
10. ठेकेदार यह सुनिश्चित करेगा कि श्रमिकों और कर्मचारियों को श्रम कानूनों के अनुसार न्यूनतम मजदूरी का भुगतान किया जाए। सभी आवश्यक सुरक्षा उपकरणों आदि के साथ कार्य के निष्पादन के दौरान निर्धारित मानदंडों के अनुसार एल एजेंसी द्वारा मापी गई सभी सुरक्षा का पालन किया जाएगा। निष्पादन एजेंसी सुरक्षा मानदंडों और 1 व्यावसायिक रूप से जिम्मेदार होगी।-संबद्ध मुआवजे आदि के सख्त पालन के लिए एकमात्र तकनीकी

Sign & Stamp of Agency



११. एजेंसी को काम पूरा होने के दिनों के भीतर भुगतान के लिए आईआईएसईआर पुणे को माप और 30 सार पत्रक प्रस्तुत करना चाहिए।
१२. एजेंसी को कार्य के निष्पादन के दौरान सभी सुरक्षा उपायों का पालन करना होगा, कोई भी दुर्घटना होने पर एजेंसी की जिम्मेदारी होगी।

Terms and Conditions:


1. The applicant should be approved and eligible contractors registered with anyone of CPWD, Maharashtra State PWD, Railways, MES in appropriate category for electrical (B&C) works **OR** specialized expert agency in field of Supply, installation testing, commissioning and maintenance of RO System or Water Coolers. Applicant should submit attested or notarized copies of the experience certificate for the work completed within last three years from client department with copy of completion certificate to along with the quotation. Bidders not meeting the minimum eligibility criteria shall be summarily rejected.
2. Time period for completion of work shall be **30 days** from the date of placing the work order by IISER Pune. The act of backing-out after opening of quotation will debar such agencies for participating in the future quotations of IISER PUNE. Bidder may e-mail queries on maintenance@iiserpune.ac.in or submit to IISER PUNE office in hard copy on all working days one day before submission date of quotation as specified above.
3. Notice Inviting Quotation (NIQ) document may be obtained from IISER PUNE at 121, Engineering Section, Main Building, IISER PUNE Campus, Dr. Homi Bhabha Road, Pashan, Pune - 411008 between 10 AM to 4 PM on all working days before date of submission. Applicant may submit quotation by obtaining NIQ document from IISER PUNE website at <http://www.iiserpune.ac.in/links/tender-notices-and-eoi>
4. All agencies need to submit their quotation in hard copy in a sealed envelope containing two separate envelopes, one envelope containing qualification documents mention in Clause 1 and second envelope containing sign, Stamp, NIQ documents with quoted rates to this office by suitable means on and before last date and time of submission. Quotation received after the date & time specified above shall not be accepted. Any delays, postal delay etc. will not be entertained. Agency should quote for all the items in the in the BOQ. The bid shall be submitted in the original Bid document (as issued by the IISER, Pune) super scribing the name of work. Rates quoted in the words shall be treated as final for deciding L1 bidder. Quotations will be opened on the same day **(27/07/2023) at 3.30 PM** in the presence of agency or their authorized representatives, if any. Please mentioned – **Technical /Qualification bid** on envelope-1 and **Financial Bid** on envelope - 2.
5. Quotations will be opened on the same day at 3.30 PM in the presence of agency or their authorized representatives, if any. The offer of the agency should be commercially clear including acceptance of all terms and conditions of this Quotation by the agency. IISER Pune reserves the right to accept or reject the quotation/s without assigning any reasons.
6. Quotations submitted with any conditions shall be treated as conditional quotations and shall be summarily be rejected by IISER PUNE.
7. Quoted rates should be inclusive of cost of all the materials, labour cost, GST, all taxes, octroi, duties, cost of sample and fees towards testing of materials in labs, royalties etc. complete

Sign & Stamp of Agency



Nothing extra shall be paid separately. No, Bidder shall contact the IISER, Pune on any matter relating to his bid from the time of the bid opening to the time of issue of work order. Any effort by the Bidder to influence the IISER's bid evaluation, bid comparison or contract award decisions, may result in the rejection of his bid.

8. All approved makes shall be as specified in BOQ and as per CPWD specifications, agency should put-up technical data and obtain prior approval on makes of various materials of IISER PUNE before taking-up work. The successful agency shall make his own arrangement for all Tools & tackles for work etc complete in view of completion of work. Electricity shall be provided free of cost to agency at one source, agency should make own arrangement to safely tap of power from source to work location. No advance payment shall be made by IISER Pune. Quoted rates should be including GST, TDS and other applicable taxes. Income Tax and labour cess will be deducted from the bills of the work.
9. Specification for the work to be carried out as per BOQ, latest CPWD specification, IS specifications & as per instruction of IISER PUNE whenever specification CPWD/ IS specification are not available.
10. The contractor shall ensure that minimum wages should be paid to the labours and employees in accordance with labour laws. All the safety measures shall be followed by the L1 agency as per prescribed norms during execution of work with all the necessary safety tools etc. Executing Agency shall be sole techno-commercially responsible for the strict adherence of safety norms and allied compensations etc
11. Agency should submit measurements and abstract sheets to IISER PUNE for the payments within 30 days from completion of work.
12. The agency should follow all safety measures during the execution of the work, any mishap happen will be responsibility of the agency.


 अधीक्षण अभियंता
 आईआईएसईआर पुणे
Superintending Engineer
IISER Pune

Sign & Stamp of Agency



Schedule of Quantity					
Name of Work:-Supply, Installation, Testing & Commissioning of 50 LPH RO Unit,150 Ltr Water Cooler for 4th and 5th Floor of Main Building,IISER Pune.					
BOQ item no.	Description	Qty	Unit	Rate of each unit (In Rupees) (In word and Figure	Amount of Total Unit(In Rupees)
A	B	C	D	E	F=CxE
1	Supply Installation Testing Commissioning of water Cooler with all required accessories to complete the job including appropriate Prefilter with its housing and Pipe at the inlet of water cooler as direction of Engineering in charge. The specification as below: 1. Storage Capacity: Minimum 150L 2. Cooling Capacity:Minimum 150Ltr/Hr 3. No. of Faucets:Minimum 02 Nos. 4. Front Tray Drain Pipe System 5. Compressor:Hermetically sealed 6. Cabinet Material : Stainless steel 7. Tank : Stainless steel 8. Water flow/level control: Float Type 9. Warranty: Minimum 1 year comprehensive on site including all components 10. Supply Voltage:230V AC 50Hz 11.Make: Voltas/Blue Star/Usha After installation the agency should submit the test report of functioning of all its parts like Float Sensor,Cooling etc. The agency should attend all problem the cooler and its component on site during warranty period on his own cost.	4	No		
2	Supply, Installation, Testing and Commissioning of UV disinfection system with specification as below: 1. UV Chamber:Cylindrical type stainless steel chamber 2. UV Lamp: Minimum 11 Watt,range of 240-280nm UV-C (UVC) band with its suitable power supply 3. Accessories:all flexible piping of suitable size for flow rate and all required accessories like SV,piping connection etc. as complete 4. Warranty: Minimum 1 year comprehensive on site including all components 5. Make for UV Lamp Only:Philips/Alpha/Konvio	4	No.		
3	Supply,Installation, Testing and Commissioning of float level switch with power adaptor etc with specification as below : 1. Switching Contacts:Minimum 5A No/NC contact to control external valve or UV lamp for water cooler The level switch should be operated on high and low level of water tank having 2 meter cable for connection with termination etc. as complete.	4	No.		
Total(Including all Taxes)					

Please note that quoted rates are inclusive of all taxes,transports,labours etc.Nothing extra shall be paid separately



TR
Superintending Engineer,
IISER, Pune