

शुद्धिपत्र 2

CORRIGENDUM 2

Date 02/09/2025

कार्य का नाम: आईआईएसईआर पुणे में किरलोस्कर निर्मित चिलर्स के लिए एटीसीएस (एटीसीएस) की आपूर्ति स्थापना परीक्षण और कमीशनिंग।

एनआईटी नंबर: 17/आईआईएसईआर/पुणे/2025-26

NAME OF WORK: Supply installation testing and commissioning of ATCS (Automatic tube cleaning system) for Kirloskar make Chillers at IISER Pune

NIT No.: 17/IISER/Pune/2025-26

विषय: बोलीदाताओं के प्रश्नों का उत्तर।

SUBJECT: Reply to bidder queries.

शुद्धिपत्र / CORRIGENDUM		
S . N .	Bidder Query	IISER Pune Reply
1	With reference to BOQ Sr. No. 02. Which mentions the specification of ATCS with the approved makes Kirloskar / Ecomax / Hydro balls , we kindly request to also include Taprogge as an approved make. The inclusion of Taprogge will allow us to submit a competitive bid and ensure a wider choice of proven and high quality equipment.	The bidder read BOQ item Sr. no. 02 as “Design Supply installation testing and commissioning of ATCS (Auto Tube Cleaning System) for the Kirloskar make chillers of capacity 470 Tr X 4 (Kirloskar Chiller model - KSC 087M) Numbers installed in a series. The system includes following items Skid, Control Panel, Injection Pump, Collection Pump, Motorised Control Valves of required sizes for supply and return line as required, Manual Valves of required sizes for supply and return line as required, Pressure Gauges, Ball Traps for supply and return line as required, Ball Collector(s) with Stand for supply and return line as required, Mesh Component, Check Valves of required size for supply and return line as required, MS pipes, elbows, flanges, gaskets, strainers of required sizes for supply and return line as required, sufficient balls for cleaning of tubes etc. Work also includes welding of pipes, taking connections from the branches of condenser pipes (inlet & outlet). Quoted rate shall be inclusive of all taxes, transportation, leads and lifts and nothing shall be paid extra on this account. Please refer Annexure A for more details. (Make - Kirloskar / Ecomax / Hydro balls /Taprogge/Thermax) “

निविदा शर्तों, ईएमडी और बीओक्यू के आइटम विनिर्देश में कोई बदलाव नहीं। बोलीदाता से अनुरोध है कि इसे नोट करें और तदनुसार बोली लगाएं।

No change in Tender conditions, EMD and other item specification of BOQ. Bidder are requested take note of it and quote accordingly.


अधीक्षण अभिपंता
Superintending Engineer
आईआईएसईआर पुणे
IISER Pune