

Minutes of Pre bid Meetings

Date 29/01/2026

कार्य का नाम: पुणे के आईआईएसईआर स्थित सी वी रमन सभागार में ऑडियो-वीडियो सिस्टम की व्यापक मरम्मत, रखरखाव और ओवरहॉल।

एनआईटी संख्या: 26/आईआईएसईआर/पुणे/2025-26

NAME OF WORK: Comprehensive repair, maintenance and overhaul of Audio video system at C V Raman Auditorium at IISER Pune

NIT No. : 26/IISER/Pune/2025-26

Subject: Reply to bidder queries

Prebid meeting for above mentioned work is held on 29/01/2026 at the Engineering Section meeting room. Please refer below mentioned IISER Pune reply to bidders queries.

Sr. No	Bidders' queries	IISER Reply
1	NIT Clause no." 3.2 Turnover: Average annual financial turnover on electrical works should be at least 50% of the estimated cost put to tender during the immediate last three consecutive financial years. The value of annual turnover figures shall be brought to current value by enhancing the actual turnover figures at a simple rate of 7% per annum." Weather turnover on electrical work only considered, please clarify?	Bidder Please read NIT Clause No:" 3.2 Turnover: Average annual financial turnover on electrical/electronic/AV system works should be at least 50% of the estimated cost put to tender during the immediate last three consecutive financial years. The value of annual turnover figures shall be brought to current value by enhancing the actual turnover figures at a simple rate of 7% per annum."
2.	BoQ item No. 12.01: a) Request for relaxing the projector specification in terms of it being IP6X certified. b) Requesting to allow the power lens function as equivalent to the 'Full motorized lens shift function' .	a) Accepted. The offered projector specification requirement of it being IP6X certified had been dropped. b) It is clarified that the Power lens / Motorized lens are synonymous to our understanding. The intent of the specification is to refer to the functionality wherein the Projector's Optical Zoom and Focus settings should be adjustable through the remote control or a network command control system (without any mechanical, manual operation). All the other specifications of the item remain unchanged.

3	<p>BoQ item No. 12.02:</p> <p>Requesting to allow the power lens function as equivalent to the 'Full motorized lens shift function' .</p>	<p>It is clarified that the Power lens / Motorized lens are synonymous to our understanding. The intent of the specification is to refer to the functionality wherein the Projector's Optical Zoom and Focus settings should be adjustable through the remote control or a network command control system (without any mechanical, manual operation).</p> <p>All the other specifications of the item remain unchanged.</p>
---	---	---

निविदा शर्तों, बीओक्यू के आइटम विनिर्देश में कोई बदलाव नहीं। बोलीदाता से अनुरोध है कि इसे नोट करें और तदनुसार बोली लगाएं।

No change in other terms and conditions, item specification of BOQ. Bidders are requested to take note of it and quote accordingly.


अधीक्षण अभियंता
Superintending Engineer