

Minutes of Pre bid Meetings

Date 16/03/2026

Subject: Reply to bidder queries

कार्य का नाम: पुणे के आईआईएसईआर की जी1 लैब 312 के लिए 100 KVA का यूपीएस उपलब्ध कराना।

NAME OF WORK: Providing 100KVA UPS for G1 lab 312 IISER Pune

NIT No. : 39/IISER/PUNE/2025-26

Prebid meeting for above mentioned work is called on 23/01/2026 at Engineering Section meeting room. No bidder attended meeting. Bidder queries are received on email. Please refer below mentioned IISER Pune reply to bidders queries.

Sr. No	Bidders' queries	IISER Reply	Remark
1	We kindly request your approval to amend the tender/specification requirements by allowing the use of Lithium-Ion batteries in place of the currently specified VRLA SMF batteries for the proposed UPS system.	Tender conditions prevails.	
2.	With reference to the above tender request you to please consider below. Valid Electrical Contractor's License of appropriate class OR engage an agency having valid electrical work license of required class through proper agreement/MoU for execution of all electrical works to the extent Rule 29 under Para III of Central Electrical Authority Regulation,2010 Attached herewith our Electrical work experience in Govt. Institute which qualifies the eligibility criteria as stated in tender.	Tender conditions prevails.	
3	In BoQ, Basic amount and total amount column shown same amount. Please clarify.	Bidder please note, updated BoQ is uploaded on CPP portal. Copy of same is attached herewith.	

निविदा शर्तों, बीओक्यू के आइटम विनिर्देश में कोई बदलाव नहीं। बोलीदाता से अनुरोध है कि इसे नोट करें और तदनुसार बोली लगाएं।

No change in terms and conditions, item specification of BOQ. Bidder are requested take note of it and quote accordingly.


अधीक्षण अभियंता
Superintending Engineer,
आईआईएसईआर पुणे
IISER Pune