

Corrigendum

Date 19/06/2026

कार्य का नाम: आईआईएसईआर पुणे में लैब 221 H क्रॉस के लिए इलेक्ट्रिकल केबल और एक्सेसरीज़, तथा पंप रूम के लिए LT केबल उपलब्ध कराना।

Name of Work: Providing electrical cable & accessories at Lab 221 h cross and LT cable for Pump room at IISER Pune

NIQ No: 54(2)/IISER/Pune/2026-27/88

विषय / SUBJECT: Reply to bidder's queries

Please refer below mentioned IISER Pune reply to bidders queries.

Sr. No	Bidders' queries	IISER Reply	Remark
1	Please Confirm, Whether Cable conductor are Copper or Aluminum for below mentioned BoQ item No. 04? "Supplying LT cable having copper conductor XLPE insulated sheathed, galvanized steel tape armoured cable with pvc outer sheathing 1.1 KV (Confirming to IS 7098 Part-II amended upto date as per the following sizes). Including the cost of all materials, labour, Handling of materials of equipment and machineries all lead lift, loading and unloading, transportation, if any other incidental charges at all level complete all as per specification and as directed by Engineer-in charge. 3.5 Core x 70 Sqmm Armoured Aluminium Cable."	Bidder please read Boq Item No 04 as "Supplying LT cable having Aluminum conductor XLPE insulated sheathed, galvanized steel tape armored cable with PVC outer sheathing 1.1 KV (Confirming to IS 7098 Part-II amended up to date as per the following sizes). Including the cost of all materials, labour, Handling of materials of equipment and machineries all lead lift, loading and unloading, transportation, if any other incidental charges at all level complete all as per specification and as directed by Engineer-in charge. 3.5 Core x 70 Sqmm Armored Aluminum Cable."	
2	Please Confirm, Whether Cable is armoured or unarmored (Flexible) for below mentioned BoQ item No. 06? Supplying LT cable having copper conductor XLPE insulated sheathed, galvanized steel tape armoured cable with pvc outer sheathing 1.1 KV (Confirming to IS 7098 Part-II amended upto date as per the following sizes). Including the cost of all materials, labour, Handling of materials of equipment and machineries all lead lift, loading and unloading, transportation, if any other incidental charges at all level complete all	Bidder please read Boq Item No 06 as "Supplying LT cable having copper conductor XLPE insulated sheathed, unarmored cable with PVC outer sheathing 1.1 KV (Confirming to IS 7098 Part-II amended upto date as per the following sizes). Including the cost of all materials, labour, Handling of materials of equipment and machineries all lead lift, loading and unloading, transportation, if any other incidental charges at all level complete all as per specification and as directed by Engineer-in charge.	

	as per specification and as directed by Engineer-in charge. 1 Core X 16 sqmm copper flexible cable”	1 Core X 16 sqmm copper flexible cable”	
3	Please Confirm, Whether Cable conductors are Copper or Aluminum for below mentioned BoQ item No. 09? Supplying LT cable having copper conductor XLPE insulated sheathed, galvanized steel tape armoured cable with pvc outer sheathing 1.1 KV (Confirming to IS 7098 Part-II amended upto date as per the following sizes). Including the cost of all materials, labour, Handling of materials of equipment and machineries all lead lift, loading and unloading, transportation, if any other incidental charges at all level complete all as per specification and as directed by Engineer-in charge. 3.5 Core x 185 Sqmm Armoured Aluminium Cable.	Bidder please read Boq Item No 09 as” Supplying LT cable having Aluminium conductor XLPE insulated sheathed, galvanized steel tape armoured cable with pvc outer sheathing 1.1 KV (Confirming to IS 7098 Part-II amended upto date as per the following sizes). Including the cost of all materials, labour, Handling of materials of equipment and machineries all lead lift, loading and unloading, transportation, if any other incidental charges at all level complete all as per specification and as directed by Engineer-in charge. 3.5 Core x 185 Sqmm Armoured Aluminium Cable.”	

निविदा शर्तों, बीओक्यू के आइटम विनिर्देश में कोई बदलाव नहीं। बोलीदाता से अनुरोध है कि इसे नोट करें और तदनुसार बोली लगाएं।

No change in terms and conditions, item specification of BOQ. Bidder are requested take note of it and quote accordingly.

Sd/-

Superintending Engineer
अधीक्षण अभियंता