

Date of Issue : 27 May 2021

CORRIGENDUM-1

NAME OF WORK : DESIGN , SUPPLY , INSTALLTION , COMMISSIONING AND VALIDATION OF CLEAN ROOM FOR DEVELOPMENT OF TISSUE CULTURE FACILITY AT IISER PUNE. NIT NO : 3/IISER/PUNE/2021-22

CORRIGENDUM :

CLARIFICATION TO BIDDERS QUERIES

Sr No	Queries by Bidder	IISER Pune Clarification
1	1. Is there any Exemption of EMD and Tender Fees for MSME Contractors.	NIT conditions prevails.
2	2. What is the warranty period required for the supply and Clean room works.	Warranty (Defect Liability Period) is specified in the tender document , bidder to refer General Conditions of Contract and quote accordingly.
3	3. As in Technical Item wise BOQ - Sr No 1.27, The Ductable Ac is mentioned as 1000 cfm only.	Capacity is adequate for required size of clean room.
4	Kindly Clarify what Clean room Class is required for above Clean room works As Then can Know the exact CFM required for the room.	Requirement is for Clean Class 100000 (One Lakh).
5	As mostly in Clean rooms, AHU is designed to maintain the Class and Static fan pressure to get the desired Conditions, acph and velocity.	Design of complete facility is in the scope of Bidder , bidder to select suitable required items from the BOQ to achieve Clean Class specified above.
6	4. Does the Main Contractor have to complete the Partition and Clean room works from the 2 Agencies i.e - GMP Technical/ Kleanzaid OR the Main Contractor can Give the works to Another Agency who can Fulfill the eligibility criteria.. -	No change in the Approved clean room agencies specified in the tender , deviation to approved makes/agencies is not allowed.
7	5. Does the Estimated Cost which is mentioned in the NIT is Inclusive of GST or is it Exclusive of it.	Yes , cost put to tender is for design, supply, installation , validation and GST. Bidder to quote rates including GST and quote accordingly.
8	6. Can the Main Contractor Go for Other makes for Supply of Items which can full the Criteria/ Standard OR the Makes only which is mentioned in the NIT .	Bidder to follow list of Approved Makes provided in the tender document , substitution/deviation not allowed.
9	We request you if you can give tender submission extension for 2-3 days as the last day of submission is today for this tender As there's still a lockdown here in Mumbai and due to the current situation, Our office is closed for today	No change in the date of submission of the tender.

10	Please confirm whether lab to be prepared is to be of BSL 3 / BSL 4 standards / clean room standards, as it is mentioned differently on every page in tender document. (screenshot and tender document attached as follows). The above query has been raised by Klenzaid's Contaminations Controls Pvt. Ltd (empanelled agency in tender) .	Laboratory is to be designed for Clean Class 100000 (One Lakh).
----	--	---

Bidders are requested to take note of it and quote accordingly.

The original tender document and conditions already in e-tender stands modified to the extent of modifications defined in above **CORRIGENDUM : 1 CLARIFICATION TO BIDDERS QUERIES** and shall form part of tender document. The bidders are requested to submit duly signed the corrigendum and all its enclosures along with the tender document on due date of submission of tender. The bidders are further requested to take note of above corrigendum and quote rates accordingly. E-copy of the Corrigendum-1 is uploaded on <https://eprocure.gov.in/eprocure/app> and Institute website at <http://www.iiserpune.ac.in/links/tender-notice-and-eoi>

**Registrar and Engineer In-Charge
IISER Pune**