



INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH

PUNE

CLARIFICATION ON TENDER NUMBER - IISER-PUR-0712-15

ITEM DESCRIPTION- (a) CREATION OF PORTA FACILITY (1000 LTRS) FOR LIQUID NITROGEN STORAGE ON MONTHLY RENTAL BASIS FOR 5 YEARS - for 2 Nos.

(b) SUPPLY OF LIQUID NITROGEN FOR 5 YEARS (Approx 70,000 Ltrs per year)

Refer our Press Tender Notice No.IISER/S&P/7/15-16 dated 4.11.2015 for items mentioned above.
Tender Reference Number - IISER-PUR-0712-15.

Pre-Bid meeting was held on November 16th, 2015 at 4.00 PM and minutes of meeting is as under.

At the outset, the Chairman welcomed all the Members and the representative of the Prospective Bidders and briefed in general the scope of the Project and thereafter requested Assistant Registrar (S&P) to brief the vendors on the salient features of the commercial terms and the indenting Officer to read out the clarification sought by the Prospective Bidders and replied thereto as detailed in Annexure -II

The representatives present were satisfied with the replies given and it was informed that the corrections / additions / clarifications given, as discussed during the Pre-Bid Conference would be hosted on the website of IISER Pune and all the Prospective Bidders are required to take cognizance of the proceedings of the Pre-Bid Conference before submitting their bids as stipulated in the Bidding Documents.

The other terms & conditions of the notice issued on our IISER website www.iiserpune.ac.in will remain unchanged. No more correspondence in this regard will be entertained

The meeting ended with vote of thanks to the Chair

16.11.2015

Sd/-
Assistant Registrar (S&P)



IISER PUNE

PRE-BID CONFERENCE FOR (a) CREATION OF PORTA FACILITY (1000 LTRS) FOR LIQUID NITROGEN STORAGE ON MONTHLY RENTAL BASIS FOR 5 YEARS - for 2 Nos. (b) SUPPLY OF LIQUID NITROGEN FOR 5 YEARS (Approx 70,000 Ltrs per year)

TECHNICAL QUERIES AND CLARIFICATION

TENDER NUMBER - IISER-PUR-0712-15

DATE : 16.11.15

S.No	Query/Clarification Sought	Clarification / Amendment
1	Liquid nitrogen transfer lines: Piping required within SMPV area or up to the lab area.	Piping shall be limited in SMPV area only with proper outlet valves and fittings to fill the dewars of pressurized and non-pressurized types.
2	Application : Only liquid nitrogen shall be used or the conversion to gaseous form is also needed.	The application is limited to liquid nitrogen only
3	Fire Safety: Fire safety equipments to be supplied by vendor or IISER	Fire safety equipments (fire extinguisher etc.) shall be in IISER's scope

4	<p>Tanks capacity:</p> <p>Tanks capacity required by IISER is 1000 ltrs x 2 nos. It was proposed that instead of this one 6000 ltrs should be installed.</p>	<p>As the requirement is for two different locations within campus, so the installation at two locations is necessary.</p>
5	<p>Civil infrastructure:</p> <p>Vendor will provide only civil drawings and assistance to erect the system or vendor is responsible for entire civil work also.</p>	<p>IISER shall provide the Civil infrastructure required. The detailed drawings are required to be submitted by vendor.</p>
6	<p>Technical bid and price bid should be considering civil cost or not</p>	<p>Refer point no.-5</p>
7	<p>CCoE approval:</p> <p>Vendor will do the entire documentation for CCoE license or vendor will do the entire licensing process provided document support by IISER.</p>	<p>Vendor will do the entire licensing procedure bearing CCoE charges. IISER shall provide the required documents for initial license and subsequent renewals.</p>



IISER PUNE

PRE-BID CONFERENCE FOR (a) CREATION OF PORTA FACILITY (1000 LTRS) FOR LIQUID NITROGEN STORAGE ON MONTHLY RENTAL BASIS FOR 5 YEARS - for 2 Nos. (b) SUPPLY OF LIQUID NITROGEN FOR 5 YEARS (Approx 70,000 Ltrs per year)

COMMERCIAL QUERIES AND CLARIFICATION

TENDER NUMBER - IISER-PUR-0712-15

DATE : 16.11.15

S.No	Query/Clarification Sought	Clarification / Amendment
	-----NIL-----	-----NIL-----