

Bid Document

Bid Details	
Bid End Date/Time	09-10-2020 11:00:00
Bid Opening Date/Time	09-10-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Human Resource Development
Department Name	Department Of Higher Education
Organisation Name	Indian Institute Of Science Education And Research (iisers)
Office Name	Pune 411008
Total Quantity	900
Item Category	Light Emitting Diode LED Fixture- LED tube light , LED Luminaire (Recessed Luminaire)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Primary product category	LED Luminaire (Recessed Luminaire)
Inspection Required	No
Estimated Bid Value	950000

EMD Detail

Advisory Bank	State Bank of India
EMD Percentage(%)	2.00
EMD Amount	19000

ePBG Detail

Advisory Bank	State Bank of India
ePBG Percentage(%)	10.00
Duration of ePBG required (Months).	36

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Director
 Pune 411008, Department of Higher Education, Indian Institute of Science Education and Research (IISERs), Ministry of Human Resource Development
 (Director Indian Institute Of Science Education And Research, Pune)

Splitting

Bid splitting not applied.

Light Emitting Diode LED Fixture- LED Tube Light (500 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Led tube light power rating corresponding Min Luminous flux	18 Watt/1800 lumen	18 Watt/1800 lumen
	Colour Temperature (K)	6300	6300
	Warranty for free replacement (Years)	2 years	2 years
CONSTRUCTIONAL	Type of Tube Light Cap	G-13 Bi-pin	*
	Ingress Protection in IP	IP 20	*
	Lamp Shell material	Polycarbonate	Polycarbonate
	LED Fixture With Al back, front with polycarbonate/Acrylic diffuser more than 85%efficiency of lig	With	*
	Light Source	SMD LED Chip	*
	LED Make	-	*
	Length of tube light (Nominal) (in mm)	1220	*
FUNCTIONAL	LED lamp efficacy (Lm/W)	100	*
	Colour Rendering Inde (CRI)	> / = 80	*
	Total Harmonics (%)	< / = 15%	*
	LED Tubelight Life of 25000 hours predicted as per TM21 Report on Data obtained as per test conducted for 6000 hours as per LM80	Yes	*
	Temperature Cycling	Yes	*

	test and supply voltage switching test (1) product shall be subjected to minus 10 degree C for 1 hour then switch to 50 degree C for 1 hour in total 5 cycles (2)30 sec ON and 30 sec Off At the end of test as per (1) and (2) no visual damage shall be observed and light should alight for more than 15 min after the test		
	Beam Angle (Degree)	> / = 120 degree	*
	Operating Voltage range (Volt)	100-300	*
	Driver Efficiency (%)	more than 85%	*
	Surge Voltage withstand (KV)	2.5 KV	*
	LED Chip Efficacy (Lm/W)	130	*
	Rated Voltage for Performance and life (Volt)	220-240	*
	Lumen Maintenance at 25 deg;C after 6000 hrs (%)	80%	*
	LED Chip Wattage (Individual) (Watt)	0,25	*
	Power Factor	> / = 0.9	*
CERTIFICATIONS	BIS Registration certificate under (CRS) number and date	-	*
	Certificare for Luminaire photometric data as per LM79	Yes	*
	Certificate No and Date of Luminaire photometric data as per LM 79 report	-	*
	Compulsory Registration and CRS of BIS for safety to IS 10322 Pt 5 Sec 1 2012	Yes	*
	EMC Test	Yes	Yes

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting	Address	Quantity	Delivery Days
-------	---------------------	---------	----------	---------------

	Officer			
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	500	15

LED Luminaire (Recessed Luminaire) (100 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	16W	16W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color temperature (+/- 500 K)	4000 deg K	*
	Type of fixture (in feet)	1x1 (for 3W to 16W)	1x1 (for 3W to 16W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*
	The luminaire body must	Yes	*

	be corrosion resistant epoxy powder coated / anodizing		
	All fasteners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)	Yes	*
OPTICAL MANAGEMENT	LED chip Efficacy (≥130 Lm/Watt for 6000 deg K, >=120 Lm/Watt for 4000 deg K, >=110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥80	*
	Beam Angle	≥120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +50 deg. C	*
	Humidity Range	10 % to 95% RH	*

PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 &TM21(Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED	Yes	*
	Availability of test Report from Central Government Lab /NABL/ILAC accredited	Yes	*

	lab to Indian Standard IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012		
	Seller has to furnish Type test report to the buyer on demand	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	LED Luminaire for recessed type shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	100	15

LED Luminaire (Recessed Luminaire) (200 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall	Yes	*

	comply as per IS:15885 (Part 2/Sec.13)		
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1))	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	12W	12W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color tempreature (+/- 500 K)	4000 deg K	*
	Type of fixture (in feet)	1x1 (for 3W to 16W)	1x1 (for 3W to 16W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*
	The luminaire body must be corrosion resistant epoxy powder coated / anadozing	Yes	*
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012	Yes	*

	lates)		
OPTICAL MANAGEMENT	LED chip Efficacy (≥ 130 Lm/Watt for 6000 deg K, ≥ 120 Lm/Watt for 4000 deg K, ≥ 110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥ 80	*
	Beam Angle	≥ 120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +50 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as	Yes	*

	rated voltage and rated power in watts shall be marked inside each LED luminaire unit		
REPORTS AND CERTIFICATIONS	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED	Yes	*
	Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standard IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
	Seller has to furnish Type test report to the buyer on demand	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	LED Luminaire for recess type shall comply with Compulsory Registration (CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	200	15

LED Luminaire (Recessed Luminaire) (100 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	36W	36W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color temprature (+/- 500 K)	6000 deg K	*
	Type of fixture (in feet)	2x2(30W to 48W)	2x2(30W to 48W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*

	The luminaire body must be corrosion resistant epoxy powder coated / anodizing	Yes	*
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	3 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)	Yes	*
OPTICAL MANAGEMENT	LED chip Efficacy (≥130 Lm/Watt for 6000 deg K, >=120 Lm/Watt for 4000 deg K, >=110 Lm/Watt for 3000 deg K)	Yes, with higher efficacy >=140 Lm/Watt	Yes, with higher efficacy >=140 Lm/Watt
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥80	*
	Beam Angle	≥120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +55 deg. C	*
	Humidity Range	10 % to 95% RH	*

PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED	Yes	*
	Availability of test Report from Central Government Lab /NABL/ILAC accredited	Yes	*

lab to Indian Standard IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012		
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for recess type shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	100	15

Special terms and conditions for category Light Emitting Diode LED Fixture- LED tube light

- 1.LED Tube Light with Fixture includes its complete fittings

Bid Specific Additional Terms and Conditions

- 1.Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
- 2.Bidders can also submit the EMD with Account Payee Demand Draft in favour of Director Indian Institute of Science Education and Research Pune payable at Pune.
Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
- 3.Bidders can also submit the EMD with Banker's Cheque in favour of Director Indian Institute of Science Education and Research Pune payable at Pune.
Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
- 4.Bidders can also submit the EMD with Payment online through RTGS / internet banking in Beneficiary name Director Indian Institute of Science Education and Research Pune. Account No. 30042605732 IFSC Code

SBIN0003552 Bank Name State Bank of India Branch address NCL Campus Branch, PUNE 411008.

Bidder to indicate bid number and name of bidding entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer along with bid.

5. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
6. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.
7. ISO 9001: The bidder must have ISO 9001 certification.

8. Malicious Code Certificate:

The seller should upload following certificate in the bid:-

(a) This is to certify that the Hardware and the Software being offered, as part of the contract, does not contain Embedded Malicious code that would activate procedures to :-

- (i) Inhibit the desires and designed function of the equipment.
- (ii) Cause physical damage to the user or equipment during the exploitation.
- (iii) Tap information resident or transient in the equipment/network.

(b) The firm will be considered to be in breach of the procurement contract, in case physical damage, loss of information or infringements related to copyright and Intellectual Property Right (IPRs) are caused due to activation of any such malicious code in embedded software.

9. OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.
10. Scope of supply (Bid price to include all cost components) : Only supply of Goods
11. Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of Director Indian Institute of Science Education and Research Pune. payable at Pune. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.
12. Successful Bidder can submit the Performance Security in the form of Payment online through RTGS / internet banking also (besides PBG which is allowed as per GeM GTC). On-line payment shall be in Beneficiary name Director Indian Institute of Science Education and Research Pune Account No. 30042605732 IFSC Code SBIN0003552 Bank Name State Bank of India Branch address NCL Campus Branch, PUNE 411008. Successful Bidder to indicate Contract number and name of Seller entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer in place of PBG within 15 days of award of contract.
13. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 10 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---